



June 20, 2019

To: Rick Preston  
Executive Director  
UDI Edmonton Region

From: Mustapha Makhdoom  
Design and Construction Standards Program Manager, UFCSD

Subject: **COE Development Inspections - Steel Trowels**

---

Just a reminder, a steel trowel finish is not permissible for air-entrained concrete as per the CSA Standards: "A steel trowel finish shall not be applied to air-entrained concrete". For further reference, please see Section 7.6.4.3.2 of the 2014 CSA Standards.

Feel free to contact me if you have any questions or concerns.

Thanks,

A handwritten signature in black ink, appearing to read "Mustapha".

Mustapha Makhdoom, P.Eng, MBA  
Design and Construction Standards Program Manager, Development Inspections  
Subdivision and Development Coordination  
Urban Form and Corporate Strategic Development